

NOTES:

TWO OUTFALLS ARE PROPOSED. THE 500 FOOT LONG, 96-INCH DIAMETER ELLIOTT WEST OUTFALL WILL DISCHARGE TREATED FLOWS 8 TO 21 TIMES PER YEAR DURING STORM EVENTS. THE 90 FOOT LONG, 120-INCH DIAMETER DENNY WAY OUTFALL WILL DISCHARGE UNTREATED CSO AN AVERAGE OF ONCE A YEAR DURING A LARGE STORM EVENT.

MARINE OUTFALLS

MONTGOMERY WATSON